



Colorimetric Parameters

Chromaticity Coordinate: $x=0.4350$ $y=0.3972$ / $u'=0.2523$ $v'=0.5184$
 CCT=2976K (Duv=-0.0025) Dominant WL: $L_d = 583.9\text{nm}$ Purity=49.8%
 Peak WL: $L_p = 644.2\text{nm}$ FWHM=185.4nm
 Render Index: $R_a = 96.5$ Render Index: AvgR = 96.3
 R1 = 97 R2 = 99 R3 = 97 R4 = 93 R5 = 96 R6 = 97 R7 = 96
 R8 = 97 R9 = 96 R10 = 98 R11 = 89 R12 = 97 R13 = 97 R14 = 98 R15 = 97

Photometric & Radiometric Parameters

Flux=274.3 lm Eff.:58.02 lm/W $F_e = 1.142$ W

Electrical parameters

V=24.00 V I=0.1970 A P=4.728 W PF=1.000 F=0.00 Hz

LEVEL:OUT WHITE:ANSI_3000K

Status: Integral T = 42 ms $I_p = 49108$ (75%)

Test Mode: Accuracy Test; Sensitivity = High; Tecool: ON

Model: XFL-TW-2414-24022-24/3595-SP005

Test By: ***

Temperature: 23Deg

Manufacturer:

Assessor: damin

Date: 2020-06-12 16:45:48

Humidity: 55%

Remarks:

TM30

